

I bought it:

The manual says otherwise:




7.1 Go to Initialization Mode

1. Turn on the power to this controller. The instrument goes to the PV/SV display after confirming input type symbol and input range.
2. Press the SET key for five seconds to go to the Parameter Setting Mode from the PV/SV display.
3. Press the SET key until "LCK" (Set Data Lock display) will be displayed.
4. The high-lighted digit indicates which digit can be set. Press shift key to high-light the hundreds digit. (The section in each image of the controller shows the digits which are not high-lighted.)



5. Press the DOWN key to change 1 to 0.



6. Press the SET key to store the new set value. The display goes to the next parameter, and the Initialization mode is unlocked.

I bought it:



The manual says otherwise:


7.3 Initial Setting Menu

Display flowcharts in Initialization mode are shown in the following.

Do not change to the section parameters and any parameter in the Initialization mode which is not described in the initial setting menu below. It may result in malfunction or failure of the instrument.

PV/SV display mode or Parameter setting mode

Press the shift key while pressing the SET key for five seconds with the unlocked.



These MENU items are not present in the instruction at all:

